

OFFICE USE ONLY
Log No. 29288
Permit No. _____
Basin 89-WASH

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER MIKE BROWN ADDRESS 3345 WATKINS
50-442-22 checked
2. LOCATION 1/4 Sec. 6 T. 16 N/S R. 20 E E WASH County
PERMIT NO. 3135

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------|--------------|------|-----|------------|
| Brown Clay | | 0 | 3 | |
| Sand | | 3 | 5 | |
| Brown Clay | | 5 | 8 | |
| Sand | | 8 | 18 | |
| Brown Clay | | 18 | 31 | |
| Sand | | 31 | 56 | |
| Brown Clay | | 56 | 58 | |
| Sand | | 58 | 75 | |
| Gray Clay | 78 | 75 | 81 | |
| Gray Sand | 84 | 81 | 105 | |
| Gray Clay | 102 | 105 | 110 | |

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 110 feet
Casing record 110
Weight per foot 9 Thickness 156
Diameter From To
6 5/8 inches 0 feet 100 feet
..... inches feet feet
Surface seal: Yes No Type CEMENT
Depth of seal 55 feet
Gravel packed: Yes No
Gravel packed from 55 feet to 110 feet
Perforations:
Type perforation MILL ST
Size perforation 3 3/2
From 75 feet to 110 feet
From feet to feet

Please Replace
Current
Scanned Image
with this log

Date started 1
Date completed

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
Static water level 10 Feet below land surface 10
Flow 25 G.P.M. 25
Water temperature Cold ° F. Quality UNKNOWN

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ROYCE BRIDGES
Address 12000 SO. VIRGINIA
Nevada contractor's license number

Nevada driller's license number 1287
Signed Royce Bridges
Date 11-21-87

BAILER TEST

| | | | | |
|-------------|-----------------|------|-------|-------|
| G.P.M. | Draw down | feet | | hours |
| G.P.M. | Draw down | feet | | hours |
| G.P.M. | Draw down | feet | | hours |