

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9565

PRINT OR TYPE ONLY Z3BCD

1. OWNER DAN GARY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11545 Deodar 1440 Antelope Valley Road
Reno, NV 89506 Reno, NV 89506
 2. LOCATION SW 1/4 NW 1/4 Sec. 23 T. 22N N/S R. 19 E Washoe County
 PERMIT NO. 79-470-040 91 Parcel No. Red Oak East (Antelope Valley) #198 per 4 Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soft brown sand		0	6	6
Brown sandy clay		6	35	29
Soft zone		35	36	1
Brown sandy clay		36	51	15
Soft zone		51	53	2
Brown sandy clay		53	88	35
Green granite sands with clay streaks		88	101	13
Soft zone	X	101	106	5
Green granite sands with clay streaks		106	116	10
Soft zone, brown med. sand	X	116	129	13
Brown clay		129	137	18
Spft zone	X	137	145	18
Green granite sands		145	151	6

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 151 feet
 _____ inches
 _____ inches
 Casing record 151' steel casing installed
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>151</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 151 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 99 feet to 145 feet
 From _____ feet to _____ feet

Date started 10-26-87, 19____
 Date completed 10-27-87, 19____

9. WATER LEVEL
 Static water level 7.6 feet below land surface
 Flow 52 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Dilling, Inc.
 Contractor
 Address P.O. box 12370, Reno, NV 89510
 Contractor
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada contractor's driller's number 908
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 923
 Signed Steve C. Hedman
 By driller performing actual drilling on site or contractor
 Date October 30, 1987

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours