

OFFICE USE ONLY  
 Log No. 29311  
 Permit No. \_\_\_\_\_  
 Basin 8-101  
 NOTICE OF INTENT NO. 9747

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER LANNIE REEVES ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1188 ROBERSON LANE 5843 MACPHERSON LANE  
Fallon, Nv. 89406 Fallon, Nv. 89406  
 2. LOCATION SW 1/4 Sec. 20 T. 19 N/S R. 28 E. Churchill County  
 PERMIT NO. NONE 08-153-14 NONE  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN</u>	<u>0</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>CLAY + SAND BROWN</u>		<u>5</u>	<u>18</u>	<u>13</u>
<u>GRAVEL</u>	<u>14</u>	<u>18</u>	<u>19</u>	<u>1</u>
<u>CLAY, BROWN</u>		<u>19</u>	<u>40</u>	<u>21</u>
<u>GRAVEL + SAND, BROWN</u>	<u>10</u>	<u>40</u>	<u>43 1/2</u>	<u>3 1/2</u>

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 43 1/2 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record + 18" to 43 1/2  
 Weight per foot 17.02 Thickness .250  
 Diameter From To  
6 inches + 18" feet 43 1/2 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type VENT  
 Depth of seal 25 feet  
 Gravel packed: Yes  No   
 Gravel packed from 42 1/2 feet to 43 1/2 feet  
 Perforations:  
 Type perforation Jorch  
 Size perforation 5/8" x 4"  
 From 40 1/2' feet to 43 1/2' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11-7 1987  
 Date completed 11-9 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>15</u>	<u>6</u>	<u>2</u>
<u>Set Pump at 30'</u>			
<u>Draw pump over 15 gpm</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold Quality EXCELLENT

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Water-Rite Well Drilling  
 Address P.O. Box 883 Fallon, Nv. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 0023978  
 Nevada contractor's driller's number issued by the Division of Water Resources 1475  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475  
 Signed Arnold W. Olson  
 By driller performing actual drilling on site or contractor  
 Date 11-9-87