

ARAA

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9520

1. OWNER Neil and Sharon Weaver
MAILING ADDRESS 4130 Kings Canyon Rd Carson City, Nv 89701
ADDRESS AT WELL LOCATION 4130 Kings Canyon Rd Carson City, Nv 89701

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 15 N/S R. 19 E Ormsby
PERMIT NO. 07-071-17 - Cirrus Parcel # 2 County _____
Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Air Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Green yellow & brown broken rock with brown dirt		0	8	8
Yellow clay & dirt with some broken rock		8	47	39
Green yellow brown broken rock		47	126	79
Yellow & white clay		126	156	30
Green yellow & white coarse sands some fine		156	205	49
Dark green light green & white fractured rock		205	215	10
Gray white clay & some sand		215	218	3
Hard fractured green white & black rock		218	275	57
T.D. <u>275</u>				

8. 10"-60" WELL CONSTRUCTION

Diameter 6 1/8 inches Total depth 275 feet
Casing record 6 5/8 & 5 inches
Weight per foot 10.78 & 6.96 Thickness .156 & .134

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>218</u> feet
<u>5</u> inches	<u>215</u> feet	<u>275</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
Depth of seal 53 feet
Gravel packed: Yes No
Gravel packed from 53 feet to 218 feet

Perforations: Type factory
Size perforation 3/32 X 3
From 198 feet to 218 feet
From 215 feet to 275 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 11/19/87, 19____
Date completed 11/23/87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. 100 WATER LEVEL
Static water level _____ feet below land surface
Flow 5 G.P.M. _____ P.S.I.
Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 625 Spice Islands Dr. Suite L Sparks, Nv 89431
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada contractor's driller's number 1132
issued by the Division of Water Resources
Nevada driller's license number issued by the 1511
Division of Water Resources the on-site driller
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date 11/30/87