WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29326
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7581

1. OWNER Gary Williams
MAILING ADDRESS P.O. Box 1035
Gard. NV 89410

ADDRESS AT WELL LOCATION 395 South of Gardnerville

2. LOCATION SW ¼ NE ¼ Sec. 10 T. 12 N/S R. 20 E. Douglas County

PERMIT NO. 36402 (Issued by Water Resources) | 27-200-15 (Parcel No.) | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay & Sand | | 0 | 15 | |
| Clay & gravel | X | 15 | 30 | |
| Clay & Sand | X | 30 | 35 | |
| Clay & gravel | X | 35 | 120 | |
| Clay | X | 120 | 140 | |
| Clay & gravel | XX | 140 | 185 | |
| Clay | XX | 185 | 205 | |
| Clay & gravel | XX | 205 | 220 | |

Date started 10-1, 1987
Date completed 10-17, 1987

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | [illegible] | | |
| | 50 | 126' | 7½ HRS |

BAILER TEST
G.P.M. 15+ Draw down 0 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 50 [illegible] feet
8 inches
inches
Casing record
Weight per foot Thickness .250

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 220 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation hand cut with cutting torch
Size perforation 6" X 5/32"
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 10 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rauchack Drilling Inc (Contractor)
Address 1578 Chiquita de Minden NV 89423 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada contractor's driller's number issued by the Division of Water Resources #1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen (By driller performing actual drilling on site or contractor)
Date 10-24-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627