WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29332
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9378

1. OWNER Ken Olsen
MAILING ADDRESS Gardnerville, Nevada
ADDRESS AT WELL LOCATION Oul Street Gardnerville, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 17 T. 12 N/S R. 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 27-644-17 (Parcel No.) Chambers Field Area (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with gravels, to 4" and Sand		0	9	9
Pea gravel and Sand, 1st water at 16 feet	✓	9	81	72
Pea gravel to 3/4" with Course Sand	✓	72	103	31
T.D. 103 feet				

Date started Nov 30, 1987
Date completed Dec 1, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clear water to remove Mud & gravel Pack			
25 plus GPM from 80'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 103 feet
..... inches
..... inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	103 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 5 feet to 103 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 82 feet to 103 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 16 feet below land surface
Flow 25+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co (Contractor)
Address 5551 Hwy 50 E #3 Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton Batts (By driller performing actual drilling on site or contractor)
Date Dec 2, 1987

(Rev. 10-83) USE ADDITIONAL SHEETS IF NECESSARY (O)-627