WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29349
Permit No. 48609
Basin 10-117 FISH LAKE VALLEY

1. OWNER Fish Lake Valley Cemetery ADDRESS Dyer Nev 89010

2. LOCATION NE ¼ SW ¼ Sec. 24 T. 2 S N/S R 35 E. Esmeralda County
PERMIT NO. 48609

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☑ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial		1	32	32
Boulders		32	36	4
Clay Rock + Gravel	✓	36	132	96
Gravel + Rock	✓	132	136	4
Saturated Clay + Rock	✓	136	158	22

Date started 11/13, 1987
Date completed 11/15, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 158 feet
Casing record
Weight per foot ..... Thickness 3/16

Diameter	From	To
6 inches	0 feet	158 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 46 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 158 feet

Perforations:
Type perforation Machine
Size perforation ⅛ x 2
From 118 feet to 158 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.S. Wright
Address HCR15 Dyer Nev 89010
Nevada contractor's license number 5566
Nevada driller's license number 1108
Signed W.S. Wright
Date 11/24/87

USE ADDITIONAL SHEETS IF NECESSARY

O-627