



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7788

PRINT OR TYPE ONLY

1. OWNER Jerry Cross ADDRESS AT WELL LOCATION 3 miles North of Bar-O Ranch
 MAILING ADDRESS 14 Ranch Montello, Nv.
Tuscarora, Nv.
 2. LOCATION SE 1/4 SW 1/4 Sec. 3 T. 37 N/S R69 E. 2150 County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other 7.5"

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty</u>		<u>0</u>	<u>5</u>	
<u>clay green</u>		<u>5</u>	<u>85</u>	
<u>CLAY SAND</u>	<u>X</u>	<u>85</u>	<u>90</u>	
<u>GREEN CLAY</u>		<u>90</u>	<u>110</u>	
<u>loose gravel</u>	<u>X</u>	<u>110</u>	<u>-</u>	

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 124 feet
 Casing record 188
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6</u> inches	<u>71</u> feet	<u>124</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type gravel
 Depth of seal 55 feet
 Gravel packed: Yes No native
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation torch cut - factory slot
 Size perforation _____
 From 104 feet to 124 feet
 From _____ feet to _____ feet

Date started 11-18- 1986
 Date completed 11-20- 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 6.2 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature calc. ° F. Quality good (tested)

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name R.V. Reynolds Contractor
 Address Wells, Nv. Contractor
 Nevada contractor's license number 019410
 Nevada contractor's drillers number 1390
 Nevada driller's license number 1390 Actual Driller
 Signed [Signature] Contractor
 Date 11-23-86

DRILLER TEST
 G.P.M. 15+ Draw down 20 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours