WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29361
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6946

1. OWNER Southern California Edison Co.
MAILING ADDRESS P.O. Box 800
Rosemead, CA 91770

ADDRESS AT WELL LOCATION Southern California Edison Company Mohave Generating Station
2700 Edison Rd. Laughlin, NV 89029

2. LOCATION NW ¼ NW ¼ Sec. 22 T 32S N/S R 66 E Clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly silty sand, med-course		0	150	150
Sandy gravel, med. cobbles		150	190	40
Cobbly gravelly sand, med.-course		190	275	85
Sandy gravel, med-fine		275	309	34

RECEIVED
NOV 2 0 1987
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Sept. 29, 1987
Date completed Oct. 2, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	50	1	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 309 feet
inches
inches
Casing record PVC Screen & Blank
Weight per foot ..... Thickness .....

Diameter	From	To
5½ inches	0 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Sand 50%-Cement
Depth of seal 12 sacks/yd feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 260 feet to 165 feet

Perforations:
Type perforation slotted PVC
Size perforation .040
From 185 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 180 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 76 °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David H. Stewart
Address P.O. Box 2067, Grants, N.M. 87021
Nevada contractor's license number issued by the State Contractor's Board 0017868 Class ASub6
Nevada contractor's driller's number issued by the Division of Water Resources 1447
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1447
Signed [signature]
By driller performing actual drilling on site or contractor
Date 11-14-87

(Rev. 11-85) MH 47

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627