WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 29390
Permit No.
Basin 184-SPRING V.

NOTICE OF INTENT NO. 6025

1. OWNER Frehner Construction Company
MAILING ADDRESS 124 West Brooks Avenue
North Las Vegas, Nevada 89030

ADDRESS AT WELL LOCATION Spring Valley

2. LOCATION NE ¼ SW ¼ Sec. 14 T. 14 N/S R. 66 E White Pine County
PERMIT NO. Waiver No. C-33 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [X] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial Boulders & Gravel		0	70	70
Clay & Gravel		70	80	10
Boulders & Gravel		80	125	45
Clay & Gravel		125	135	10
Boulders & Gravel		135	175	40
Limestone Reef		175	190	15
Clay & Gravel		190	275	85
Sandy Clay & Gravel		275	285	10
Clay		285	295	10
Water Sand & Gravel	X	295	300	5
Sand & Clay		300	310	10
Boulders & Clay		310	372	62

Date started June 27, 19 87
Date completed June 29, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
40 H.P. Sub. Pump	180	72	12

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 372 feet
Casing record 8 In. 0 - 372
Weight per foot 16.94 Thickness .188

Diameter	From	To
8 inches	0 feet	372 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 372 feet

Perforations:
Type perforation Torch
Size perforation 3/16" x 6" 5 Rows
From 167 feet to 207 feet
From 227 feet to 354 feet
From Blank 354 feet to 372 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 285 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue, Ely, Nevada 89301 (Contractor)
Nevada contractor's license number ~~XXX~~ 14790
Nevada contractor's drillers number 641
Nevada driller's license number 641 (Actual Driller)
Signed Jerald D. Christiansen (Contractor)
Date July 13, 1987

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434