

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5871

1. OWNER SILVER-STATE MINING CORP ADDRESS AT WELL LOCATION Ruby Valley  
 MAILING ADDRESS Denver, Colo

2. LOCATION NE 1/4 NW 1/4 Sec. 36 T. 24 N/S R. 58 E White Pine County  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium		0	35	35
Pilot shale				
Oxidized		35	350	315
Pilot shale				
Fractured		350	415	65
Pilot shale				
Altered +				
Fractured	35'	415	450	35
Pilot shale				
Silicified		450	525	75
Pilot shale				
Silicified				
Altered	115	525	640	115

8. WELL CONSTRUCTION  
 Diameter hole 10 inches Total depth 640 feet  
 Casing record 640 ft  
 Weight per foot 22.5 Thickness 1.250"  
 Diameter 8 3/4 inches From 0 feet To 370 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation 1 1/2" x 3/4" w/d  
 From 370 feet to 640 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 415 feet below land surface  
 Flow 150 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 45° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name C. D. Austin Contractor  
 Address Box 894, Elko, Nev. Contractor  
 Nevada contractor's license number 0022193  
 Nevada contractor's drillers number 802  
 Nevada driller's license number 802 Actual Driller  
 Signed C. D. Austin Contractor  
 Date 12-14-87

Date started 11-17, 1987  
 Date completed 12-3, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 150 Draw down 25 feet 4 hours  
 G.P.M. 150 Draw down 35 feet 6 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours