WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29398
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9363

1. OWNER Blades Construction
MAILING ADDRESS Box 1273
Gardnerville, Nevada 12

ADDRESS AT WELL LOCATION
1059 Tanobo
Gardnerville, Nevada

2. LOCATION ~~NE~~ ¼ SE ¼ Sec. ~~23~~ T. 12 N/S R. 20 E. Douglas County
PERMIT NO. NW 23-232-04 Pine Nut Manor Sagewood
Issued by Water Resources Parcel No. (new gpn# 1220-12-710-035) Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ small, to 4" rock		0	7	7
Highly Cemented gravels, with Clay Stringers		7	210	203
Pea gravels, to 3/4 inch, with fine to course sand	✓	210	233	23
Clay Seam, Cemented gravel		233	235	2

T.D. 235'

1059 Tenabo Ln
OLD 23-232-046
~~NEW APN~~
~~1220-12-710-035~~
Legal
NW SE Sec 12 12N20E

Date started Dec 3, 1987
Date completed Dec 7, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to gravel pack & develop			
15 GPM from 210' with air for 2 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 60 inches Total depth 235 feet
9 7/8 inches
..... inches
Casing record 6 5/8 OD steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	235 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 235 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 X 3
From 214 feet to 235 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 140 feet below land surface
Flow 15 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address 5551 Hwy 50 E #3 Carson City, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed [signature]
By driller performing actual drilling on site or contractor
Date 12/8/87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627