WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 29406
Permit No.
Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5239

1. OWNER Southern California Edison
MAILING ADDRESS P.O. Box 800 Rosemead, CA 91770
ADDRESS AT WELL LOCATION Southern California Edison Co., Mohave Generating Station 2700 Edison Rd. Laughlin, NV 89029

2. LOCATION NE ¼ NE ¼ Sec. 26 T. 32S N/S R. 66 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fly ash & native soil overburden		0	43	43
Yellow to brn clay		43	95	52
Crs.sand to grvly silt		95	140	45
Grvly silt to crs. sand		140	180	40
Pea grvl. inc. tan clay		180	210	30
Well cemented gravels with clay streaks		210	267	57

RECEIVED
DEC 07 1987
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Oct. 20, 19 87
Date completed Oct. 24, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	20	57	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 15 inches Total depth 267 feet
..... inches
..... inches
Casing record 8" PVC Blank & Screen
Weight per foot ..... Thickness Sch 80

Diameter	From	To
8 inches	2' abv.gnd feet	258 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat cement 6 gal/sack
Depth of seal 0 - 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 267 feet to 160 feet

Perforations:
Type perforation slotted PVC
Size perforation .040
From 165 feet to 258 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 193 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 73 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David H. Stewart
Address P.O. Box 2067, Grants, N.M. 87021 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0017868 Class A Sub 6
Nevada contractor's driller's number issued by the Division of Water Resources 1447
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1447
Signed David H. Stewart (By driller performing actual drilling on site or contractor)
Date 12-1-87

(Rev. 11-85) MH 54 MH 54

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627