



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4633

PRINT OR TYPE ONLY

OWNER Adrian Sandoval ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION N.W. 1/4 N.W. 1/4 Sec. 25 T. 19-S N/S R. S-3 E Nye County
 PERMIT NO. _____ Issued by Water Resources Parcel No. Water Unit 4 Parcel 2 Subdivision Name Bell Vista Sub

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard pan		0	4	4
Pop Corn shale		4	12	8
Brn Clay		12	57	45
Clechia	X	57	59	2
Clay		59	97	38
Clechia	X	97	102	5
Clay		102	147	45
Clechia	XX	147	157	10
Clay		157	160	3

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 160 feet
 _____ inches
 _____ inches
 Casing record 160 x 8 5/8
 Weight per foot 14.50 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 160 feet

Perforations:
 Type perforation Tool
 Size perforation 1/8 x 6 2 Rows
 From 120 feet to 160 feet
 From _____ feet to _____ feet

RECEIVED
 NOV 03 1987
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 8-7- 1987
 Date completed 8-8- 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 40 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling Inc Contractor
 Address 4425 Stacey Ave. W. U. Nav Contractor
 Nevada contractor's license number issued by the State Contractor's Board 19219
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1081
 Signed C.B. Bejhan
 By driller performing actual drilling on site or contractor
 Date 8-15-87

BAILER TEST

G.P.M.	Draw down	feet	hours