

OFFICE USE ONLY  
Log No. 29467  
Permit No. \_\_\_\_\_  
Basin 106  
REC. 01/26/88 9809  
NOTICE OF INTENT NO. \_\_\_\_\_

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Bob Gable ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 8530 Stanton Ave.  
Buena Park Ca. 90620  
2. LOCATION N.W. 1/4 SW 1/4 Sec 210 T 10 S R 22 E Douglas County  
PERMIT NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name Halbrook Highlands

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loose shale rock / some clay</u>	<u>No</u>	<u>0</u>	<u>130</u>	<u>130</u>
<u>Sandy clay, some gravel</u>	<u>No</u>	<u>130</u>	<u>190</u>	<u>60</u>
<u>Loose rock, some gravel</u>	<u>Yes</u>	<u>190</u>	<u>210</u>	<u>20</u>

8. WELL CONSTRUCTION  
Diameter 8 inches Total depth 210 feet  
Casing record 210  
Weight per foot \_\_\_\_\_ Thickness 250  
Diameter From To  
8 inches 0 feet 210 feet  
Surface seal: Yes  No  Type concrete  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Perforations:  
Type perforation Factory saw slot  
Size perforation 1/8" x 1/3"  
From 175 feet to 210 feet

Date started 1-7- 1988  
Date completed 1-22- 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
Static water level 40 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name F.M.D.L. CO. INC. Contractor  
Address Box 92, Smith, NV 89430 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 24149  
Nevada contractor's driller's number issued by the Division of Water Resources 24149  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533  
Signed Scott Howard  
By driller performing actual drilling on site or contractor  
Date 1-25-88

BAILER TEST  
G.P.M. 25 Draw down 90 feet 4 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours