WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29475
Permit No.
Basin 8-105
NOTICE OF INTENT NO. 8366

PRINT OR TYPE ONLY

1. OWNER Jack Huffman
MAILING ADDRESS Gardnerville, Nevada
ADDRESS AT WELL LOCATION 1195 Cary Creek Court Gardnerville, NV
2. LOCATION SW ¼ SW ¼ Sec. 3 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. Cary Creek Estates (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ sand and boulders to 4'		0	10	10
Granodiorite, soft to hard, with layers of dg., white to brown color, and running dg. in lenses		10	87	77
Fractured Granodiorite		87	98	11
Fractured, hard to medium hard white to grey granite	✓	98	120	22
T.D. 120 feet				

RECEIVED JAN 28 '88 10:32 STATE ENGINEERS OFFICE

Date started Jan 18, 1988
Date completed Jan 19, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well w/ air to gravel pack and to clear out sand & fractured granite			
Blew 50+ GPM		from	100 feet

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" to 60" inches Total depth 120 feet
inches
inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 58 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 58 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3½
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 30 feet below land surface
Flow 30+ G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5351 Hwy 50 E #3 Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed Clinton K Butts (By driller performing actual drilling on site or contractor)
Date Jan 20, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627