

OFFICE USE ONLY  
 Log No. 29482  
 Permit No. \_\_\_\_\_  
 Basin 9-108  
 REC 01/20/88  
 NOTICE OF INTENT NO. 5799

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

OWNER NORMAN NEZLSON ADDRESS AT WELL LOCATION SAME AS  
 MAILING ADDRESS HWY 95-A 220 N. MARLETTE  
YRZNGZON, NV. 89447  
 2. LOCATION SW 1/4 SW 1/4 Sec. 34 T. 14 N. R. 25 E. LYON County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                 | Water Strata | From | To  | Thick-ness |
|--------------------------|--------------|------|-----|------------|
| Brown Clay + Sand        |              | 0    | 18  | 18         |
| Blue Clay + Sand         |              | 18   | 22  | 4          |
| Coarse Sand              |              | 22   | 30  | 8          |
| Green Clay + Sand        |              | 30   | 36  | 6          |
| Coarse Sand + Green Clay |              | 36   | 58  | 22         |
| Brown Sand + Brown Clay  |              | 58   | 70  | 12         |
| Brown Clay               |              | 70   | 100 | 30         |
| Coarse Sand + Gravel     | X            | 100  | 123 | 23         |

8. WELL CONSTRUCTION  
 Diameter hole 10 7/8 inches Total depth 124 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 156  
 Diameter From To  
6 7/8 inches (+) 1 feet 123 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Grout  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50' feet to 123' feet  
 Perforations:  
 Type perforation SAWED  
 Size perforation 3/32" x 3" x 6 Rows  
 From 103 feet to 123 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name OGORN RAD'S DRILLING  
162 N. BYBER LN. Contractor  
 Address YRZNGZON, NV. 89447  
 Nevada contractor's license number 15646  
 Nevada contractor's drillers number 870 + 530  
 Nevada driller's license number 530  
 Actual Driller  
 Signed Billy Ogden Contractor  
 Date 1-18-88

Date started 1-14, 1988  
 Date completed 1-18, 1988

7. WELL TEST DATA

| Pump RPM    | G.P.M.    | Draw Down | After Hours Pump |
|-------------|-----------|-----------|------------------|
| <u>3600</u> | <u>50</u> |           | <u>4 Hrs.</u>    |
|             |           |           |                  |
|             |           |           |                  |

BAILER TEST  
 G.P.M. 20 Draw down 10 feet 1/2 hour  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours