

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

01/19/88
 NOTICE OF INTENT NO. 9532

1. OWNER George Duffy ADDRESS Wild Life Rd
 MAILING ADDRESS P. O. Box 1389 7 miles East side I-80
Fernley, Nv 89408 Fernley

2. LOCATION NW NE 1/4 Sec. 27 T. 21 N/S R. 25 E. Churchill County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Mud <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic cobbles boulders & sand		0	40	40
Volcanic rock basalt hard fractured with some sand		40	108	68
Red cinders & clay		108	115	7
Reddish brown black green volcanic gravel with some very coarse white sand		115	123	8
Reddish brown black yellow volcanic rock fractured		123	136	13
Black volcanic rock hard & fractured		136	159	23
T.D. 159				

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 159 feet

_____ inches
 _____ inches

Casing record 6 5/8
 Weight per foot 10.78 Thickness .156

Diameter 6 5/8 inches From +1 1/2 feet To 158 feet

_____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet

Surface seal: Yes No Type neat cement

Depth of seal 56 feet

Gravel packed: Yes No
 Gravel packed from 56 feet to 159 feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 118 feet to 159 feet
 From _____ feet to _____ feet

Date started 1/6/88, 19____
 Date completed 1/7/88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. 50 WATER LEVEL

Static water level _____ feet below land surface
 Flow 60+ G.P.M. _____ P.S.I.
 Water temperature warm °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr. Suite L Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132
 issued by the Division of Water Resources

Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date 1/14/88