WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

MH-50

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 2940
Permit No.
Basin 14-213
Rec. 01/11/19[illegible]
NOTICE OF INTENT NO. 2940

1. OWNER Southern California Edison
MAILING ADDRESS PO Box 800
Rosemead, CA 91770
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SE ¼ Sec. 27 T 32S N/S R 66 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well rounded river gravels, ½" to 1"		0	70	70
Fine sand & some clay, less gravel		70	110	40
Increase in angular gravel, well sorted, and increase in clay		110	164	54

RECEIVED
NOV 23 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11/6, 19 87
Date completed 11/8, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	15	52	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 164 feet
..... inches
..... inches
Casing record 5" PVC blank and slotted
Weight per foot ..... Thickness Schd. 80

Diameter	From	To
5 inches	2 AGL feet	138 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat cement
Depth of seal 0-50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 140 feet to 60 feet

Perforations:
Type perforation Slotted PVC
Size perforation .040"
From 78 feet to 138 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow None G.P.M. ..... P.S.I.
Water temperature 78 °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David H. Stewart
Contractor
Address PO Box 2067, Grants, NM 87021
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0017868
Nevada contractor's driller's number issued by the Division of Water Resources 1447
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1447
Signed David H. Stewart
By driller performing actual drilling on site or contractor
Date 1/7/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627