WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29497
Permit No.
Basin 8-105
Rec 01/13/88
NOTICE OF INTENT NO. 6296

PRINT OR TYPE ONLY

1. OWNER Joanne Nunes
MAILING ADDRESS 1291 Manhattan
Gardnerville Nevada

ADDRESS AT WELL LOCATION
806 Rojo Way
Gardnerville, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 17 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. 27-095-02 Issued by Water Resources
Parcel No. 1220-17-411-003
Tierra Linda Estates Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden –		0	5	5
Clay & Gravels		5	11	6
Sand, gravel, small boulders to 6"	✓	11	45	34
Small to very small pea gravel w/sand	✓	45	88	43
Pea Gravel to 3/8"–1/2" with Course Sand	✓	88	120	32
T.D. 120 Feet				

Date started Jan 8, 19 88
Date completed Jan 11, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Initial well with bailer to open up the gravel pack developed with air			
35 GPM from 95 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 120 feet
..... inches
..... inches
Casing record 6 5/8 O.D. steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 92 feet to 112 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 14 feet below land surface
Flow 35 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACH Pump Co Contractor
Address 551 Highway 50E Carson City, Nev Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton Potts
By driller performing actual drilling on site or contractor
Date Jan 11, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 10-85) (O)-627