



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4545

PRINT OR TYPE ONLY

1. OWNER WILDA JONES ADDRESS AT WELL LOCATION 1/4 MI. NORTH OF AIRPORT, SANDY VALLEY
 MAILING ADDRESS ADA CRESTLINE RD HENDERSON, NEV. 89015

2. LOCATION SW 1/4 NE 1/4 Sec 6 T. 25 N. 37 E. CLARK County

PERMIT NO. 10 Lot 2 Issued by Water Resources Parcel No. CLD 170-81 Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	1	1
CLAY		1	36	35
CALICHE		36	38	2
SANDY CLAY		38	49	11
CALICHE	WTR	49	53	4
CONS. CLAY		53	68	15
LOOSE ROCK	WTR	68	74	6
CONS. CLAY		74	98	24
SANDY CLAY		98	111	13
CALICHE	WTR	111	115	4

8. WELL CONSTRUCTION

Diameter 14 inches Total depth 115 feet

Casing record STEEL

Weight per foot 12.5 Thickness 15/64

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>115</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 50 feet to 115 feet

Perforations:

Type perforation FLAME CUT

Size perforation 3/8 X 4 4 Rows 0.116" dia

From 75 feet to 115 feet

From _____ feet to _____ feet

RECEIVED
 JAN 14 1988

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started JAN 6, 19 88
 Date completed JAN 9, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	_____ feet	_____ hours
<u>42</u>	<u>2</u>	<u>1</u>	

9. WATER LEVEL

Static water level 31 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature 68 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.C.B.B. INC. Contractor

Address 1701 W. CHSTN BLVD LAS VEGAS NV 89102 Contractor

Nevada contractor's license number issued by the State Contractor's Board 210203

Nevada contractor's driller's number issued by the Division of Water Resources 1352

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352

Signed Robert Spurlock
 By driller performing actual drilling on site or contractor

Date Jan 12 - 88