

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5425

PRINT OR TYPE ONLY

OWNER Joe Rubin. ADDRESS AT WELL LOCATION Red. Couch
+ Chiefton

2. LOCATION SE 1/4 NE 1/4 Sec. 6 T. 20S N/S R. 60 E Clark. County
 PERMIT NO. 51762 Issued by Water Resources Parcel No. 450-050-029 Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & Gravel</u>		<u>0</u>	<u>9</u>	<u>9</u>
<u>Sandy Clay & Rock</u>		<u>9</u>	<u>420</u>	<u>411</u>
<u>Small Gravel</u>	<u>WB</u>	<u>420</u>	<u>428</u>	<u>8</u>
<u>Cemented Conglomerate</u>		<u>428</u>	<u>433</u>	<u>5</u>
<u>Sand & Gravel</u>	<u>WB</u>	<u>433</u>	<u>460</u>	<u>27</u>
<u>Cemented Conglomerate</u>		<u>460</u>	<u>465</u>	<u>5</u>
<u>Sand & Gravel</u>	<u>WB</u>	<u>465</u>	<u>500</u>	<u>35</u>

RECEIVED
 JAN 11 1988
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 12-26, 1987
 Date completed 1-4, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 500 feet
 Casing record 500 ft 8 7/8 inch
 Weight per foot 17.11 Thickness 156

Diameter	From	To
<u>8 7/8</u> inches	<u>0</u> feet	<u>500</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 500 feet
 Perforations:
 Type perforation SAW
 Size perforation 1/8 inch by 3 inch
 From 460 feet to 500 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 380 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name St H Drilling
 Address HCR Box 70906 Pahrump NV.
 Nevada contractor's license number 22659
 Nevada contractor's drillers number _____
 Nevada driller's license number 1426
 Signed Steve Rasmussen Actual Driller
 Date 1-4-88
 Contractor