WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 29563
Permit No.
Basin

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 4450

1. OWNER SHADOW MTN. ~~ESTATES~~ HOMES, INC.
MAILING ADDRESS P.O. BOX 1513
PAHRUMP, NEV. 89041

ADDRESS AT WELL LOCATION
1330 W. RAY
PAHRUMP, NEV.

2. LOCATION N.W. ¼ S.W. ¼ Sec. 6 T. 20 N/S R. 53 E. NYE County
PERMIT NO. ..... Issued by Water Resources
LOT 8 BLK 6 Parcel No.
SHADOW MOUNTAIN ESTATES Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN CALECHE		1	38	37
HARD BROWN CLAY		38	44	6
BROWN CALECHE		44	76	32
HARD BROWN CALECHE		76	81	5
BROWN CALECHE		81	90	8
HARD BROWN CALECHE		90	97	7
BROWN CALECHE		97	116	19
HARD BROWN CALECHE		116	123	7
BROWN CLAY		123	140	7

RECEIVED
FEB 8 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-13, 19 88
Date completed 1-20, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 140 feet
Casing record 140 ft. 8 5/8" O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" x 8"
From 70 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 34 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING (Contractor)
Address P.O. BOX 157 PAHRUMP, NEV. (Contractor)
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 - STAN HARDIN (Actual Driller)
Signed ..... (Contractor)
Date 1-22-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434