WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29564
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4451

1. OWNER SHADOW MTN HOMES, INC. | ADDRESS AT WELL LOCATION 1300 W. KAY
MAILING ADDRESS P.O. BOX 1513 PAHRUMP, NEV. 89041 | PAHRUMP, NEV.

2. LOCATION N.W. ¼ S.W. ¼ Sec. 6 T. 20 N/S R. 53 E NYE County
PERMIT NO. 1 (Issued by Water Resources) | LOT 6 BLK 6 (Parcel No.) | SHADOW MTN. ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN CALICHE		1	36	35
HARD BROWN CLAY		36	45	9
BROWN CALICHE		45	76	31
HARD BROWN CALICHE		76	80	4
BROWN CALICHE		80	90	10
HARD BROWN CALICHE		90	95	5
BROWN CALICHE		95	117	22
HARD BROWN CALICHE		116	120	4
BROWN CLAY		120	140	20

RECEIVED
FEB 8 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-26, 1988
Date completed 1-28, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 140 feet
Casing record 140 FT. 8 5/8" O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 80 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 34 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING (Contractor)
Address P.O. BOX 157 PAHRUMP, NEV. 89041 (Contractor)
Nevada contractor's license number 7429-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 - STAN HARDIN (Actual Driller)
Signed [signature] (Contractor)
Date 1-29-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434