

OFFICE USE ONLY  
 Log No. 29576  
 Permit No. \_\_\_\_\_  
 Basin E-103

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 9588

PRINT OR TYPE ONLY

1. OWNER Wayne Campos ADDRESS AT WELL LOCATION 1225 Deer Run Rd  
 MAILING ADDRESS 1225 Deer Run Rd  
Carson City, Nv 89701

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 15 N/S R. 20 E Carson City County  
 PERMIT NO. 10-083-04 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown yellow white & green sands with traces of green rock		0	38	38
Brown yellow white green coarse sands		38	87	49
Brown clay with traces of sands		87	94	7
Brown yellow & white sands		94	100	6
Green brown reddish brown yellow		100	115	15
Brown clay volcanic sands & gravels		115	156	41
Sticky brown clay		156	163	7
Very coarse volcanic sands with traces of brown clay		163	204	41
T.D.			204	

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 199 feet  
 Casing record 6 1/2 I.D. fiberglass Threaded/Coupl  
 Weight per foot hot resin Thickness .250

Diameter	From	To
<u>7</u> inches	<u>+1</u> feet	<u>199</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type neat cement  
 Depth of seal 56 feet  
 Gravel packed: Yes  No   
 Gravel packed from 56 feet to 200 feet

Perforations:  
 Type perforation factory  
 Size perforation fiberglass screen .030  
 From 179 feet to 199 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2/12/88, 19\_\_\_\_  
 Date completed 2/16/88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Flow 30+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 108 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
 Address 625 Spice Islands Dr. Suite L Sparks, Nv. 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 2/16/88