WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29577
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9739

1. OWNER Mike Tschopp
MAILING ADDRESS P.O. Box 61
Silver Springs, NV. 89429

ADDRESS AT WELL LOCATION
Curry Rd, Fallon

2. LOCATION NE ¼ NW ¼ Sec. 2 T. 17 N/S R. 28 E. Churchill County

PERMIT NO. none (Issued by Water Resources) | 06-553-32 map (Parcel No.) | none (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	6	6
Clay, Brown		6	42	
Clay, Black		42	100	58
Clay, Gray		100	160	60
Sand & Clay, odor strong		160	161	1
Clay, gray		161	168	7
Clay, Black		168	178	10
Clay, gray		178	195	
gravel gray, would not clean up.	25	195	195½	½
Clay & gravel		195½	202	
Sand fine, green would not clean up.	+2	202	205	3
Sand & clay mixed		205	214	9
Clay, gray		214	215	1
Sand, fine, gray would not clean up.	20	215	218	3
Sand & clay gray would not clean up		218	224½	
Clay, gray		224½	245	
Clay, Black		245	248	
Clay, green, Hard		248	253	
Clay, Black		253	255	2
Clay, gray, Hard		255	280	
Sand, fine, Brown	30	280	283	3
Cemented gravel, green		283	284	1

Date started 1-7-88, 19
Date completed 2-2-88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	15gpm	15	5½ hrs.
Set pump @ 75 feet			
do not pump over 10gpm.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 284 feet
inches
inches
Casing record + 18" to 284
Weight per foot 17.02 Thickness 1250

Diameter	From	To
6 inches	+18" feet	284 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 25 feet
Gravel packed: Yes ☒
Gravel packed from 282 feet to 284 feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 4"
From 281 feet to 284 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

STATE ENGINEER'S OFFICE '88 FEB -5 A10:15

9. WATER LEVEL
Static water level 30 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good, Light Salt Taste

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, NV. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald V. Olson (By driller performing actual drilling on site or contractor)
Date 2-2-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627