WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29548
Permit No.
Basin 8-102

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5781

1. OWNER BILL BETTS
MAILING ADDRESS 7994 SPRINGFIELD SILVER SPRINGS LOT 23
ADDRESS AT WELL LOCATION LOT 23 SAGE BRUSH SUB. #1

2. LOCATION SE ¼ SE ¼ Sec. 18 T. 17 N/S R. 25 E. LYON County
PERMIT NO. (Issued by Water Resources) 17-292-05 (Parcel No.) SAGE BRUSH SUB #1 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COARSE SAND		0	25	25
COARSE SAND w/ CLAY STRATAS		25	35	10
COARSE SAND		35	50	15
BROWN CLAY		50	52	2
GREEN COARSE SAND		52	58	6
GREEN COARSE SAND AND GREEN CLAY		58	66	8
COARSE SAND		66	105	39
GREEN CLAY + GREEN SAND		105	120	15
GRAVEL AND COARSE SAND	X	120	143'6"	23'6"

Date started 1-27, 1988
Date completed 1-30, 1988

'88 FEB 18 A10:08
RECEIVED STATE ENGINEERS OFFICE

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	33	5'	12

BAILER TEST
G.P.M. 22 Draw down 3 feet 1/2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 144'6" feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	(+) 1 feet	143'6" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 143'6" feet

Perforations:
Type perforation SAWED
Size perforation 3/32" X 3" X 6 ROWS
From 123'6" feet to 143'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 31' 6" feet below land surface
Flow G.P.M. P.S.I.
Water temperature COLD° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS DRILLING (Contractor)
Address 162 N. BYBEE LN YERINGTON, NV. 89447 (Contractor)
Nevada contractor's license number 15646
Nevada contractor's drillers number 634 & 870
Nevada driller's license number 634 (Actual Driller)
Signed [signature] (Contractor)
Date 2-1-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434