WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 29579
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 5782

1. OWNER BILL BETTS
MAILING ADDRESS 7994 SPRINGFIELD
SILVER SPRINGS, NV.

ADDRESS AT WELL LOCATION LOT # 24
OF SAGE BRUSH SUB. # 1

2. LOCATION SE ¼ SE ¼ Sec. 18 T. 17 N/S R. 25 E. LYON County
PERMIT NO. (Issued by Water Resources) 17-292-06 (Parcel No.) SAGE BRUSH SUB #2 (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0 | 15 | 15 |
| SAND AND CLAY | | 15 | 28 | 13 |
| COURSE SAND AND GRAVEL | | 28 | 38 | 10 |
| COURSE SAND AND CLAY | | 38 | 55 | 17 |
| COURSE SAND | | 55 | 90 | 35 |
| GREEN CLAY AND SAND | | 90 | 110 | 20 |
| BROWN CLAY AND SAND | | 110 | 120 | 10 |
| COURSE SAND AND GRAVEL | X | 120 | 130 | 10 |
| GRAVEL AND COURSE SAND | X | 130 | 143'4" | 13'4" |

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 144'4" feet
Casing record
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | (+) 1 feet | 143'4" feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 143'4" feet

Perforations:
Type perforation SAWED
Size perforation 3/32" x 3" x 6 ROWS
From 123'4" feet to 143'4" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 31' 6" feet below land surface
Flow G.P.M. P.S.I.
Water temperature COLD ° F. Quality GOOD

Date started 2-7, 1988
Date completed 2-12, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 22 Draw down 3 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS DRILLING (Contractor)
Address 162 W. BYBEE AV. YERINGTON, NV. 89447 (Contractor)
Nevada contractor's license number 25646
Nevada contractor's drillers number 870 + 634
Nevada driller's license number 634 (Actual Driller)
Signed [signature] (Contractor)
Date 2-15-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434