WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

29618
OFFICE USE ONLY
Log No.
Permit No. 54708
Basin 212

1. OWNER SAM PAYAN ADDRESS

2. LOCATION SW ¼ SE ¼ Sec. 14 T. 22 N. S. R. 61 E. CLARK County
PERMIT NO. 54708

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay Brn		0	3	3
White Clay w/s gravels		3	87	84
Brn Clay w/small gravel		87	170	83
Brn Clay		170	190	20
Brn Clay w/seams of coarse gravel	X	190	255	65
Brn Volcanic Rock	X	255	300	45

RECEIVED
FEB 17 1988
Div. of Water Resources
Branch Office - Los Vegas, NV

Date started Jan 17, 1988
Date completed Jan 20, 1988

7. ~~WELL TEST DATA~~

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Test			
900 CFM	250 PSI	300'	
45 gpm	After 3 hrs.		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 300 feet
Casing record
Weight per foot 14.11 Thickness .0156

Diameter	From	To
8 5/8 inches	+1 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 60' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation ¼ x 8
From 200 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature WARM F. Quality UNKNOWN

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name St D Drilling
Address 630 Rolling ave
Nevada contractor's license number 0027030
Nevada driller's license number 1475
Signed Dean Mitchell
Date 1-10-88

USE ADDITIONAL SHEETS IF NECESSARY

O-627