

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 10136

1. OWNER BRENT & JEAN NORRIS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 680 Emerson Way 445 Hill Lane
Sparks, NV 89431 Verdi, NV
 2. LOCATION SW 1/4 SE 1/4 Sec 18 T 19N N/S R 18 E Washoe County
 PERMIT NO. 038-224-14 Sierra Glenn
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown clay		1/2	3	2 1/2
Granite boulder		3	5	2
Boulders-gravels, some brown clay		5	68	63
Soft zone (app. 6GPM)	X	68	71	3
Boulders & gravel		71	90	19
Soft zone, sand and graveels		90	96	6
Gray clay		96	244	148
Dark brown clay		244	278	34
Gray clay		278	286	8
Soft zone	X	286	296	10
Gray clay		296	298	2
Dark brown clay		298	305	7
Soft zone	X	305	318	13
Gray clay		318	325	7

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 325 feet
5 inches
5 inches

Casing record 335' steel casing installed.
 Weight per foot _____ Thickness .156 & .134

Diameter	From	To
6 5/8 inches	0 feet	156 feet
5 9/16 inches	146 feet	325 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 325 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 285 feet to 325 feet
 From _____ feet to _____ feet

Date started 3-28-88, 19____
 Date completed 3-29-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 1.07 feet below land surface
 Flow 60+ G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. box 12370, Reno, Nv 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada contractor's driller's number 908 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Feltman by driller performing actual drilling on site or contractor
 Date March 31, 1988