WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29678
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9382

1. OWNER Painter Construction
MAILING ADDRESS Box 1201
Zephyr Cove, Nevada

ADDRESS AT WELL LOCATION 1202 Holly Court
Gardnerville, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 12 N/S R. 19 E Douglas County
PERMIT NO. (Issued by Water Resources) 19-051-29 (Parcel No.) Holly Court (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, blow sand with large granite boulders		0	11	11
light to dark brown D.G. with small granite boulders, slightly cemented		11	40	29
Compacted D.G., dark to light tan		40	94	54
Hard fractured granodiorite carrying H_2O Major water at 114-115 ft	✓	94	120	26
T.D. 120 Ft				

Date started March 30, 1988
Date completed March 31, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean Water to remove mud & gravel pack. Developed with 250 psi 450 CFM air for 2 hrs to Clean			
28-30 GPM from 100 ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 120 feet
Casing record 6 5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 94 feet to 114 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 27 feet below land surface
Flow 30+ G.P.M. P.S.I.
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 559 Hwy 88 #3 Carson City, NV 89701 (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Winston R. Britt (Actual Driller)
Date March 31, 1988 (Contractor)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434