

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9553

1. OWNER Larry Mackie ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 870 Irvin Ct 1240 Mineral Flat Rd  
Hayward, Ca 94541

2. LOCATION SE 1/4 NE 1/4 Sec. 13 T. 22 N/S R. 19 E Washoe County \_\_\_\_\_  
PERMIT NO. \_\_\_\_\_ Parcel No. 79-430-22-431-26 Subdivision Name Red Rock Estates # 752  
Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan brown & white DG		0	3	3
Light green white & tan DG compact		3	19	16
Tan yellow white with traces of green		19	66	47
Green with white black specs fractured granite		66	218	152
T.D. 218 feet				

8.10" - 60' WELL CONSTRUCTION  
Diameter 8 1/2 inches Total depth 218 feet  
7 7/8 inches  
6 5/8 inches

Casing record 6 5/8  
Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>218</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
Depth of seal 53 feet  
Gravel packed: Yes  No   
Gravel packed from 53 feet to 218 feet

Perforations:  
Type perforation factory  
Size perforation 3/32 X 3  
From 198 feet to 218 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3/31/88, 19\_\_\_\_  
Date completed 4/1/88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

9. WATER LEVEL  
Static water level 185 feet below land surface  
Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling & Well Service Inc.  
Contractor  
Address 625 Spice Islnds Dr. Suite L Sparks, NV  
Contractor 83431

Nevada contractor's license number issued by the State Contractor's Board 15291  
Nevada contractor's driller's number issued by the Division of Water Resources 1132  
Nevada driller's license number issued by the Division of Water Resources 1511  
Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
Date Roger M. Thrall 4/5/88

BAILER TEST

G.P.M.	Draw down	feet	hours