

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 9551

1. OWNER Larry and Linda Beck ADDRESS AT WELL LOCATION 35 Rio Del Sol
 MAILING ADDRESS 2942 Springland Dr. Spanish Springs
Sparks, Nv 89431
 2. LOCATION 1/4 SW 1/4 Sec. 31 T. 21 N/S R. 21 E. Washoe County
 PERMIT NO. 076-390-47 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Reddish brown green volcanic cobble with brown clay		0	8	8
Light brown yellow sandy clay		8	12	4
Brown yellow green white decomposed rock with brown clay		12	135	123
Tan white brown sand with light brown clay		135	248	113
Green rock with green clay		248	258	10
T.D. 258'				

8.10" = 60' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 256 feet

Casing record 6 5/8" inches
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1</u> feet	<u>256</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 256 feet

Perforations:
 Type perforation 3/32 X 3 factory
 Size perforation 3/32 X 3
 From 215 feet to 256 feet
 From _____ feet to _____ feet

Date started 3/29/88, 19____
 Date completed 3/30/88, 19____

9. WATER LEVEL

Static water level 110 feet below land surface
 Flow 20 G.P.M. P.S.I. _____
 Water temperature cold °F Quality _____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr. Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 4/5/88

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours