WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29702
Permit No.
Basin 8-106

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6301

1. OWNER Mr & Mrs O'Bannion
MAILING ADDRESS Space #31
Helbrook Junction, Nevada

ADDRESS AT WELL LOCATION 1444 Penrod Court
(Helbrook, at Nevada)
Gardnerville, Nevada 89410

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 10 N/S R. 22 E Douglas County
PERMIT NO. (Issued by Water Resources) 37-121-02 (Parcel No.) None (Subdivision Name) Parcel 2-A

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, boulders		0	28	28
Gravel, loose Hard with fractures from 207 to 240		28	240	212
1st Water at 207 ft. Water in all fractures to 237 ft	✓			
T.D. 240 Ft				

Date started March 11, 1988
Date completed March 21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with air to remove mud & gravel pack making 20 GPM from 220 With 250 psi air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" to 6" inches Total depth 240 feet
Casing record 6 5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 200 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 158 feet below land surface
Flow 20 G.P.M. ..... P.S.I.
Water temperature Cool° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5551 Hwy 50 E #3 Carson City, Nev (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Gordon R Betts (Actual Driller)
Date March 21, 1988 (Contractor)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434