WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 29703
Permit No.
Basin 8-105

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 9923

1. OWNER PHIL WILLIAMSON
MAILING ADDRESS 601 Sonoma
Carson City, Nevada

ADDRESS AT WELL LOCATION Johnson Lane Area
1538 JONES ST
MINDEN NEVADA

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 14 N/S R. 20 E Douglas County

PERMIT NO. ____ Issued by Water Resources | 21-211-33 Parcel No. | SIERRA VIEW Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ N4D

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blue sand		0	8	8
Sand, fine to Coarse with gravel		8	85	77
Gravel interspersed with Clay		85	107	22
Tight Clay, Grey		107	124	17
Sand with pea gravels	✓	124	131	7
Small to Medium pea gravels	✓	131	157	26
Clay, tight		157	160	3
T.D. 160 feet				

Date started 3/21, 1988
Date completed 3/23, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean water to gravel pack & remove drill mud developed with air	15-18 GPM		from 110 feet

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 12" to 60' inches Total depth 160 feet
Casing record 6 5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 3/32 x 3
From 135 feet to 155 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 100 feet below land surface
Flow 15-18 G.P.M. ____ P.S.I.
Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H pump Co
Contractor
Address 5551 Hwy 50 E #3 Carson City NV
Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Actual Driller
Signed Clinton R Butts
Contractor
Date 3/24/1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434