WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29704
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9364

1. OWNER Painter Construction
MAILING ADDRESS P.O. BOX 1201
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 1203 Holly Court
Gardnerville, NV

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 12 N/S R. 19 E Douglas County
PERMIT NO. (Issued by Water Resources) 19-051-28 (Parcel No.) Holly Court (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ HUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/boulders & compacted sand		0	15	15
D.G. with medium to large boulders		15	60	45
Tight, hard D.G. white to grey		60	78	18
D.G. with medium to hard granite boulders, dark grey to white		78	94	16
Hard to medium granite with fractures with water test fracture 116'	✓	94	120	26
T.D. 120 FT				

Date started Mar. 24, 1988
Date completed Mar. 26, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud with clean H_2O Developed well with air to remove sand & gravel pack			
35+ GPM from 100 FT			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 to 60 inches Total depth 120 feet
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 95 feet to 115 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow 35+ G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5551 Hwy 50 E #3 Carson City, NV 89701 (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472 (Actual Driller)
Signed (Contractor)
Date March 27, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434