R.D. REYNOLDS DRILLING

(702) 752-3205
P.O. Box 402
Wells, Nevada 89835

½ mile South on Hyw. 93

Thomas Gallagher
Hydraulic Engineer

3/27/88

Re. Norman D. Glaser well abandonment

The 4" well was grouted from 20 foot depth to the ground surface with 2" inch trimming using neat cement. The 5' foot culvert was plugged with 3 ft of concrete from a depth of 12 ft to 9 ft, 9 ft depth to 2 ft depth was filled with native clay, 2 ft to 1 ft above the ground surface was concrete. Concrete was 9 sack per yard.

Sincerely,

Ray D. Reynolds