WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29465
Permit No.
Basin 9-107

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9035

1. OWNER Robert E. L. Wright
MAILING ADDRESS 201 Mary St. Carson City, Nevada
ADDRESS AT WELL LOCATION Box 13 Jessen Road Smith, Nev. 89430

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 12 N/S R. 24 E. Lyon County

PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam topsoil		0	10	10
Hardpan		10	18	8
Sandy clay		18	75	57
More sandy clay/gravel	Yes	75	125	50
Blue, gumbo clay		125	195	70
More soft clay and coarse sand and silt	Yes	195	280	85
Brown gumbo clay		280	315	35
Coarse sand and gravel	Yes	315	393	78

Date started 2-22, 1988
Date completed 3-1, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20+ Draw down 20 feet 4 hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 393 feet
..... inches
..... inches
Casing record 393
Weight per foot ..... Thickness .250

Diameter	From	To
8 inches	0 feet	393 feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from — feet to — feet

Perforations:
Type perforation Factory saw slot
Size perforation 3" x 3/32"
From 353 feet to 393 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 68 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDL CO. INC (Contractor)
Address Box 92, Smith, Nv. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 24149
Nevada contractor's driller's number issued by the Division of Water Resources 24149
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed Scott Christensen (By driller performing actual drilling on site or contractor)
Date 3-15-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627