WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29763
Permit No. 51164, 52025, 52026
Basin 4-49

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Rex Clariage & Associates
MAILING ADDRESS P.O. Box 248
Elko, Nevada 89801

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 17 T 34 N/S R. 55 E Elko County
PERMIT NO. W-237 App. 51164 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test XX
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	7	7
Tan sandy clay & gravel		7	195	188
Gravel		195	208	13
Clay & gravel		208	235	27
Gravel	x	235	278	43
Sandy clay, some gravel	x	278	305	27
Cemented gravel		305	338	33
Gravel & sand	x	338	374	36
Cemented gravel		374	415	41
Sandy clay		415	433	18
Gravel, some sand	x	433	474	41
Sandy clay		474	480	6

Date started January 19, 19 88
Date completed February 4, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION 0 to 305 12" 305 to 480 8"
Diameter hole 12 inches Total depth ..... feet
Casing record Steel
Weight per foot ..... Thickness .219

Diameter	From	To
8 5/8 inches	+1 feet	304 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation .....
Size perforation .....
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 180 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elsing Drilling & Pump Co., Inc. Contractor
Address P.O. Box 919 Twin Falls, Idaho 83303-0919 Contractor
Nevada contractor's license number 0017177
Nevada contractor's drillers number 1295
Nevada driller's license number 945 Actual Driller
Signed Elsing Drilling + Pump Inc Contractor
Date February 13, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434