

OFFICE USE ONLY
 Log No. 29993
 Permit No. 50652
 Basin 1
 NOTICE OF INTENT NO. 5192

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

Belle & Joe Chohanen
 1. OWNER Robeco Construction
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION Jonathan and Las Vegas Blvd

2. LOCATION SE 1/4 NE SE 1/4 Sec 5 T 300 N/S R 61 E CLARK County _____
 PERMIT NO. 50652 Parcel No. 23 Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Rock		0	4	4
Cemented Conglom.		4	16	12
Sand & Rock		16	94	78
Gravel & Sandy Rd. Clay		94	165	71
Cemented Conglom.		165	171	6
Gravel & Sandy Rd. Clay		171	310	139
Fragmented cemented Conglomerate	X	310	328	18
Gravel & Sandy Rd. Clay		328	365	37
Fragmented Cemented Conglomerate		365	427	62
Red Sand Stone	X	427	440	13
Fragmented Cemented Conglomerate	XX	440	600	160

8. WELL CONSTRUCTION
 Diameter 10" inches Total depth 600' feet
 _____ inches
 _____ inches
 Casing record 6-5/8"
 Weight per foot 10.78 Thickness 156

Diameter	From	To
<u>6-5/8"</u> inches	<u>0</u> feet	<u>600</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Torch
 Size perforation 1/16" X 6" X 4 around
 From _____ feet to _____ feet
 From 432' feet to 600' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
 MAR 31 1988
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started March 23, 1988
 Date completed March 25, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR</u>	<u>35</u>	<u>?</u>	<u>1</u>

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 280' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC Contractor
 Address 4547 VALLEY VIEW BLVD Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0018917
 Nevada contractor's driller's number issued by the Division of Water Resources 1301
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date MAR 29 1988