

OFFICE USE ONLY
 Log No. 29804
 Permit No. _____
 Basin 162



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6437

PRINT OR TYPE ONLY

1. OWNER DAN HEITZ ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION N.E. 1/4 NE 1/4 Sec 10 T. 21S N/S R. 53 E County _____
 PERMIT NO. _____ Parcel No. Block 9 Lot 8 Subdivision Name Plantation Estates

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	4	4
Caliche		4	12	8
Clay		12	42	30
Caliche	WB	42	46	4
Clay		46	84	38
Caliche	WB	84	91	7
Clay		91	110	19
Caliche	WB	110	126	16
Clay		126	140	14

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 140 feet

Casing record 140 ft 8 5/8 inch

Weight per foot 14.11 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 50 feet to 140 feet

Perforations:

Type perforation SAW

Size perforation _____

From 100 feet to 120 feet

From _____ feet to _____ feet

RECEIVED

APR 11 1988

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 3-22 1988
 Date completed 3-25 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 36 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature 66.1 °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name S+H Drilling Contractor

Address HCR Box 70906, Pahang NV Contractor

Nevada contractor's license number issued by the State Contractor's Board 22059

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1426

Signed Steve Hamann By driller performing actual drilling on site or contractor

Date 3-28-88

