

Log No. 29812  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER William Richie ADDRESS AT WELL LOCATION Hg Fern  
 MAILING ADDRESS Branch Road

2. LOCATION NW 1/4 NW 1/4 Sec 15 T 21S N/S R. 54 E Nye County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	16	16
Consolid Sand & Gravel		16	23	7
Sand & Gravel		23	60	37
Sandy Clay & Rock		60	73	13
Consolid Sand & Gravel		73	86	13
Sandy Clay & gravel		86	120	34
Fractured Conglomerate WB	WB	120	152	32
Sandy Clay & Gravel		152	178	26
Sand & gravel	WB	178	183	5
Sandy Clay		183	196	13
Sand & gravel	WB	196	210	14

8. WELL CONSTRUCTION  
 Diameter 12 inches Total depth 210 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 210 Ft. 8 5/8  
 Weight per foot 14.11 Thickness 156  
 Diameter From To  
8 5/8 inches 0 feet 210 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 210 feet  
 Perforations:  
 Type perforation SAW  
 Size perforation 1/8 inch by 3 inch  
 From 190 feet to 160 feet  
 From 190 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 APR 11 1988  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 2-10, 1988  
 Date completed 2-14, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 101 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SFH Drilling Contractor  
 Address HCB 65 Box 70906 Pahrump NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1426  
 Signed Steve Ramon  
 By driller performing actual drilling on site or contractor  
 Date 3-26-88