

OFFICE USE ONLY
 Log# No. 29818
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 5372

WELL DRILLER'S REPORT
 Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Lionel George Vozina ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 19 T. 21S N/S R. 59 E. Mye County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	3	3
Caliche		3	26	23
Limestone		26	29	3
Clay		29	56	27
Caliche	WB	56	61	5
Clay		61	80	19
Caliche	WB	80	93	13
Clay		93	101	8
Limestone	WB	101	106	5
Clay		106	121	15
Caliche	WB	121	128	7
Clay		128	136	8
Caliche	WB	136	153	17
Clay		153	160	7

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 160 feet

Casing record 160 Ft. 8 5/8 inch

Weight per foot 14.11 Thickness 1.56

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____

Depth of seal _____ feet

Gravel packed: Yes No

Gravel packed from 50 feet to 160 feet

Perforations:

Type perforation SAW

Size perforation 1/8 inch by 3 inch

From 120 feet to 140 feet

From _____ feet to _____ feet

RECEIVED

APR 1 1988

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 2-1 1988
 Date completed 2-1 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 43 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAH Drilling Contractor

Address HCR Box 70008 Reno NV 89501

Nevada contractor's license number issued by the State Contractor's Board 22059

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed Steve Hammett
 By driller performing actual drilling on site or contractor

Date 3-26-88