WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28846
Permit No.
Basin 3-101
NOTICE OF INTENT NO. 8973

PRINT OR TYPE ONLY

1. OWNER Richard & Allen Bachla
MAILING ADDRESS P.O. Box 2353
Fallon, NV. 89406
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 29 T 19 N S R. 28 E Churchill County
PERMIT NO. None (Issued by Water Resources) | 1 of 2nd parcel map (Parcel No.) | Machado Subdivision (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Brown		0	52	52
Clay, Gray		52	60	8
Gravel & Clay				
Mixed, Gray		60	74	14
Gravel, Brown	18	74	95	21
Clay, Brown		95	103	8
Sand, Gray, odor		103	110	7
Clay, Gray		110	127	17
Gray, Sand, odor		127	131	4
Sand, Brown		131	135	4
Gravel & Sand	13'-4"	135	136'-11"	2

RECEIVED '88 MAY -5 AM 10:02 STATE ENGINEER'S OFFICE

Date started 4-28, 1988
Date completed 5-3, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	20	46'-8"	4 hrs

Set Pump at 100'
Pump over 15 gpm
Use a 12 gpm. Flow control

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 136'-11" feet
..... inches
..... inches
Casing record Steel
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+18" feet	135'-11" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 135'-11" feet to 136'-11" feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 4"
From 133'-11" feet to 136'-11" feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 13'-4" feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, NV. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada driller's license number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald J. Allen (By driller performing actual drilling on site or contractor)
Date 5-3-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627