

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO 10871

1. OWNER Robert L. Hyde ADDRESS AT WELL LOCATION Same as above
 MAILING ADDRESS 5495 Weaver Rd
Fullerway Wd 189406

2. LOCATION N 1/2 SE 1/4 Sec. 19 T. 18 N/S R. 29 E. Churchill County
 PERMIT NO. none Issued by Water Resources 205820 Subdivision Name none
 Parcel No. File

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Clay, brown</u>		<u>2</u>	<u>30</u>	<u>28</u>
<u>Sand, fine, brown</u>	<u>15</u>	<u>30</u>	<u>32</u>	<u>2</u>
<u>Clay, white</u>	<u>0</u>	<u>32</u>	<u>60</u>	<u>28</u>
<u>Clay, black</u>		<u>60</u>	<u>81</u>	<u>21</u>
<u>Sand + clay black</u>				
<u>Strong silt</u>		<u>81</u>	<u>92</u>	<u>11</u>
<u>Clay, gray</u>		<u>92</u>	<u>115</u>	<u>23</u>
<u>Clay, brown</u>		<u>115</u>	<u>119</u>	<u>4</u>
<u>Sand brown + gray and gravel</u>	<u>19 1/2</u>	<u>119</u>	<u>123 1/2</u>	<u>4 1/2</u>

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 123 1/2 feet

Casing record Steel

Weight per foot 17.02 Thickness 12.50

Diameter	From	To
<u>6</u> inches	<u>+18"</u>	<u>123 1/2</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type neat

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 122 1/2 feet to 123 1/2 feet

Perforations:
 Type perforation Torch
 Size perforation 3/32 x 4"

From 120 1/2 feet to 123 1/2 feet

RECEIVED
 APR 27 1988
 STATE ENGINEER'S OFFICE

Date started 4-22-88, 19____
 Date completed 4-25-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>20</u>	<u>25 1/2</u>	<u>3 1/2</u>
<u>Set pump @ 60 ft</u>			
<u>don't pump over 159 AM</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
.....
.....
.....

9. WATER LEVEL
 Static water level 9 1/2 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good, faint odor

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water-Rite Well Drilling
 Address P.O. Box 883 Fullerway Wd, 89406
 Nevada contractor's license number issued by the State Contractor's Board 0023978
 Nevada contractor's driller's number issued by the Division of Water Resources 1473
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
 Signed Gerald H. Oren
 By driller performing actual drilling on site or contractor
 Date 4-25-88