WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29850
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

36BB

NOTICE OF INTENT NO. 8968

1. OWNER Louie Guazzine
MAILING ADDRESS 3855 Austin Hwy. Fallon, Nv. 89406
ADDRESS AT WELL LOCATION 25 S. Harmon Rd. Fallon, Nv. 89406

2. LOCATION NW ¼ SW ¼ Sec. 36 T. ~~18~~ 19N N S R. 29 E Churchill County
PERMIT NO. none (Issued by Water Resources) — (Parcel No.) — (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	1	1
Clay Brown		1	17	16
Sand, med fine, Brown		17	21	4
Sand + pea gravel	5'-6"	21	21'-5½"	5½"
Clay - greenish		22	on.	

Note: Need a seal Waver on seal. In this area the deeper well have alway showed salt.

Gerald W. Olson

The Bottom of the screen has a P.V.C. cap.

RECEIVED
STATE ENGINEERS OFFICE
88 MAY -2 A10:12

Date started 4-26, 1988
Date completed 4-27, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	15	8'-9"	4

Set Pump at 16½ ft from ground level.
Dont Pump over 12 G.P.M.

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 21½ feet
..... inches
..... inches
Casing record Steel to 17'-10½" plastic screen
Weight per foot 16' of 5" Thickness

Diameter	From	To
6 inches	+17" feet	16'-5½" feet
5 PVC SCREEN inches	-5' feet	21'-5½" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 15 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Sawed.
Size perforation .020
From 16'-5½ feet to 21'-5½" feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 5-6 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good.

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, Nv. 89406 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0023978

Nevada contractor's driller's number issued by the Division of Water Resources 1473

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473

Signed Gerald W. Olson
By driller performing actual drilling on site or contractor

Date 4-27-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627