

OFFICE USE ONLY  
 Log No. 29855  
 Permit No. \_\_\_\_\_  
 Basin 101-CARSON DESERT

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9921

PRINT OR TYPE ONLY

1. OWNER Jeanne Rondo ADDRESS AT WELL LOCATION Same as owner  
 MAILING ADDRESS 3006 Bottom Rd. Fallon, NV. 89406  
 2. LOCATION N 1/2 NE 1/4 Sec. 31 T. 19 S. R. 28 E. Churchill County Thurman  
 PERMIT NO. none Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Subdivision Lot 29

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>overburden</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Clay, Brown</u>		<u>5</u>	<u>22</u>	
<u>Clay &amp; sand mixed</u>				
<u>Brown</u>		<u>22</u>	<u>40</u>	
<u>Clay Gray</u>		<u>40</u>	<u>60</u>	<u>20</u>
<u>Sand &amp; Gravel</u>				
<u>Brown</u>	<u>15</u>	<u>60</u>	<u>83</u>	<u>23</u>
<u>Clay, Brown</u>		<u>83</u>	<u>105</u>	
<u>Clay, gray</u>		<u>105</u>	<u>133</u>	
<u>Sand, gray, fine</u>		<u>133</u>	<u>143</u>	<u>10</u>
<u>Sand &amp; Gravel</u>	<u>13'40"</u>	<u>143</u>	<u>148 1/2</u>	<u>5 1/2</u>
<u>Clay, gray</u>		<u>148 1/2</u>		

RECEIVED  
 APR 22 1988  
 STATE ENGINEER'S OFFICE

Date started 4-13 1988  
 Date completed 4-19 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>15</u>	<u>92</u>	<u>3</u>
<u>Set Pump at 135'</u>			
<u>don't Pump over 15 gpm.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 148 feet  
 Casing record Steel  
 Weight per foot 17.02 Thickness 1.250  
 Diameter From 6 inches + 1/8" feet 148 feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 147 feet to 148 feet  
 Perforations:  
 Type perforation Touch  
 Size perforation 5/32 x 4"  
 From 145 feet to 148 feet

9. WATER LEVEL  
 Static water level 13 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality Good, light odor

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Water-Rite Well Drilling Contractor  
 Address P.O. Box 883 Fallon, NV. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 0023978  
 Nevada contractor's driller's number issued by the Division of Water Resources 1473  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473  
 Signed Herald D. Olson  
 By driller performing actual drilling on site or contractor  
 Date 4-20-88