

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 10138

PRINT OR TYPE ONLY

1. OWNER PAUL SEEKINS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. box 5046 2540 Rio Seco Lane _____
Sparks, NV 89432 Sparks, NV _____
 2. LOCATION SE 1/4 NE 1/4 Sec. 32 T. 21N N/S.R. 21 E Washoe County
 PERMIT NO. 76-380-57 Spanish Springs _____
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Sandy brown clay		1/2	15	14 1/2
Brown clay		15	26	11
Dark brown sandy clay w/gravels		26	181	155
Light brown sandy clay w/gravels		181	255	74
Brown volcanic rock		255	361	106
Soft zone (NO WATER)		361	363	2
Brown volcanic rock		363	369	3
Brown volcanic rock w/clay streaks		369	465	96
Soft zone (NO WATER)		465	466	1
Brown volcanic rock		466	476	10
Streak of red clay		476	477	1
Red volcanic rock with some clays		477	545	68
Purple volcanic rock		545	565	20
Fracture rock	X	565	588	23
Purple volcanic rock		588	600	12

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 600 feet
 _____ inches
 _____ inches
 Casing record 600' steel casing installed.
 Weight per foot _____ Thickness .156
 Diameter From To
6 5/8 inches 0 feet 600 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal _____ 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 600 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 555 feet to 595 feet
 From _____ feet to _____ feet

Date started 4-10-88, 19____
 Date completed 4-13-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 475 feet below land surface
 Flow 10.8 G.P.M. P.S.I. _____
 Water temperature cold°F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Hedman By driller performing actual drilling on site or contractor
 Date April 14, 1988