

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9552

1. OWNER Sharon Daniels/Will Painter ADDRESS AT WELL LOCATION 2100 Crossover  
 MAILING ADDRESS 2100 Crossover  
Reno, Nv 89510

2. LOCATION SENE 1/4 Sec. 26 T. 22 N/S R. 21 E. Washoe County  
 PERMIT NO. 77-160-26 - Palomino Valley Unit 1 Subdivision Name 26-2-1-5  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Mud <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Reddish Brown clay green tan white & black sands		0	17	17
Green tan white black sands & gravel		17	73	
Light brown clay green yellow & white sands		73	138	65
Green silts & clay with yellow white & black sands		138	185	47
Brown silty clay with yellow & white sands	brown	185	193	8
Green clay with some brown yellow green & black sands		193	260	67
T.D. 260'				

8. 12 1/4" - 60' WELL CONSTRUCTION

Diameter 10 5/8 inches Total depth 260 feet

Casing record 8 5/8 inches

Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>8 5/8</u> inches	<u>+2</u> feet	<u>260</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout

Depth of seal 53 feet

Gravel packed: Yes  No

Gravel packed from 53 feet to 260 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3

From	feet to	feet
<u>120</u>	<u>140</u>	feet
<u>180</u>	<u>200</u>	feet
_____	_____	feet
_____	_____	feet
_____	_____	feet

RECEIVED  
 APR 21 1988  
 STATE ENGINEER'S OFFICE

Date started 4/13/88, 19\_\_\_\_  
 Date completed 4/15/88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. 100 WATER LEVEL

Static water level 100 feet below land surface

Flow 40+ G.P.M. P.S.I. \_\_\_\_\_

Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.

Address 625 Spice Islands Dr Suite L Sparks, NV 89431

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on site driller 1511

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor

Date 4/20/88