

OFFICE USE ONLY  
 Log No. 29877  
 Permit No. \_\_\_\_\_  
 Basin G-89

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 10146

PRINT OR TYPE ONLY

1. OWNER GARY & MARY ROMERO ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2945 ~~XXXXXXXXXX~~ Falcon Street 3125 Holly Lane  
Carson City, NV 89701 Carson City, NV 89701  
 2. LOCATION SW 1/4 NW 1/4 Sec. 5 T. 16N N/S R. 20 E Washoe County  
 PERMIT NO. 50-450-03 Washoe Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other  Air

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with some gravels & sand		1	30	29
Weathered granite		30	57	27
Soft zone, clay streaks		57	58	1
Weatherd granite		58	79	21
White granite		79	118	39
Gray granite		118	132	14
Soft zone (NO WATER)		132	135	3
Weathered granite		135	146	11
Gray granite		146	159	13
Fracture (app. 3-6GPM) X		159	161	2
Gray hard granite		161	186	25
Weathered zone soft		186	188	2
White granite		188	211	33
Gray hard granite		211	243 1/2	32 1/2
<del>XXXXXXXXXXXX</del>				
<del>XXXXXXXXXX</del>				
Small fracture (NO WATER)		243 1/2	244	1 1/2
Weathered softer granite		244	258	14
Gray hard granite		258	277	4
Softer weathered granite X		277	281	4
Gray hard granite		281	300	19

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 300 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 300' steel casing installed.  
 Weight per foot \_\_\_\_\_ Thickness .156  
 Diameter 6 5/8 inches From 0 feet To 300 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement  
 Depth of seal 51 feet  
 Gravel packed: Yes  No   
 Gravel packed from 51 feet to 300 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 152 feet to 172 feet  
 From 272 feet to 292 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-28-88 19\_\_\_\_  
 Date completed 4-30-88 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BASE TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Flow 14 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno NV 89510 Contractor  
 Nevada contractor's license number 22549 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources 923  
 Signed Wayne C. Helman  
 By \_\_\_\_\_ driller performing actual drilling on site or contractor  
 Date May 2, 1988